CHANGE 28 - PERMANENT ABOVE GROUND SWITCHGEAR HOUSE FOR POWER SUPPLY - PATRINGTON

For more detailed mapping please see our interactive map on **www.nephccp.co.uk**

Location	Approx 2km east of Patrington, off Wakefield Lane. Co-located alongside the proposed Patrington AGI.
Local Authority	East Riding
Parish	Welwick Parish Council
Reason for change	Further technical work
Land requirement	Permanent
Size	0.06 hectares
Description of change	As described in the PEIR and at statutory consultation, the Project requires the installation of twin power cables from Salt End to Easington. These would run alongside the pipeline. The power cables would require a switchgear house to enable testing, isolation, fault-finding, and operational management of the cable circuits. A switchgear house is required east of Patrington next to the proposed Patrington Above Ground Installation (AGI) on land which was within the draft Order Limits shown at statutory consultation. The switchgear house will be located next to the AGI. The AGI has been repositioned in response to landowner feedback. It is now tucked closer to the field boundaries. The switchgear house would comprise: • A shed type building up to 4.5m x 4.5m and 4.5m high. • Space for parking • Security fencing. The switchgear house would be unlit, unstaffed (except for very occasional inspections) and would not generate any noise. When the pipeline is decommissioned the station would be dismantled and ground reinstated. Environmental information relating to this change can be found on **www.nephccp.co.uk**